

Borough of Buena Municipal Utilities Authority Sewer Tap Installation Policy

The Borough of Buena Municipal Utilities Authority requires all plumbers at the time of tapping sewer main to install a one way cleanout, ie: combination Y & 1/8 facing towards the sewer main. This cleanout shall be located in the road right of way and accessible to the BBMUA. The riser shall have a ferrous metal ie: cast iron lateral lid with a brass plug. Also, the sewer saddle must be approved ie: stainless steel strap by the BBMUA. These requirements must be inspected by the BBMUA at the time of installation. This inspection is in addition to the required plumbing inspection of Buena Borough.

ie:

